


FUSED DISCONNECT  
SUPPLIED BY OTHERS  
AS PER NEC.


ACME TRANSFORMERS



NR. PRINT PART NUMBER	Single Trans. KVA	MFG PART NUMBER	BUCK OUTPUT MAX. KVA
1019050	0.5KVA	T-1-81058	?7KVA
	0.7KVA	T-1-81059	?11KVA
	1.0KVA	T-1-13073	?15KVA
1019102	2.0KVA	T-1-13075	?30KVA
	3.0KVA	T-1-13076	?45KVA

FUSED DISCONNECT  
SUPPLIED BY OTHERS  
AS PER NEC.


JEFFERSON TRANSFORMERS



NR. PRINT PART NUMBER	Single Trans. KVA	MFG PART NUMBER	BUCK OUTPUT MAX. KVA
	0.5KVA	216-1131	?7KVA
	0.7KVA	216-1141	?11KVA
1019022	1.0KVA	216-1151	?15KVA
1019023	2.0KVA	216-1171	?30KVA
1019022A	3.0KVA	216-1181	?45KVA

FUSED DISCONNECT  
SUPPLIED BY OTHERS  
AS PER NEC.


SQUARE-D TRANSFORMERS



NR. PRINT PART NUMBER	Single Trans. KVA	MFG PART NUMBER	BUCK OUTPUT MAX. KVA
	0.5KVA	500SV43B	?7KVA
	0.7KVA	750SV43B	?11KVA
	1.0KVA	1S43F	?15KVA
	2.0KVA	2S43F	?30KVA
	3.0KVA	3S43F	?45KVA

FUSED DISCONNECT  
SUPPLIED BY OTHERS  
AS PER NEC.

MICRON TRANSFORMERS/HPS



NR. PRINT PART NUMBER	Single Trans. KVA	MFG PART NUMBER	BUCK OUTPUT MAX. KVA
	0.5KVA		?7KVA
	0.7KVA		?11KVA
1019022	1.0KVA	J001K1E1A1A02	?15KVA
	2.0KVA		?30KVA
	3.0KVA		?45KVA

PART NAME BUCK TRANSFORMER

VALID FROM	THIS DRAWING AND/OR SPECIFICATION IS THE PROPERTY OF M & R PRINTING EQUIPMENT INC. IT IS ISSUED IN STRICT CONFIDENCE AND SHALL NOT BE REPRODUCED, COPIED OR DISCLOSED TO OTHERS OR USED AS THE BASIS FOR THE MANUFACTURE OR SALE OF APPARATUS WITHOUT THE PERMISSION OF THE OWNER.	SCALE	NONE	WHERE USED	SINGLE PHASE
VALID TO		 M&R PRINTING EQUIPMENT, INC. 1 N. 312 Main Street Gen. Ellyn, Illinois 60129	DWG No.	BuckTransB	
DWN BY			JZ	DATE	3/2/98
ENG APP.				DATE	
		SHEET	1 OF 1	REV.	AV3